



HENNEPIN COUNTY— PUBLIC SWIMMING POOL DAILY LOG *Keep logs for 6 years

Pool Name _____ Month _____ Year _____ Size of Pool (gallons) _____ Flow Rate Minimum (GPM) _____

Date	DAILY TESTS							OTHER TESTS		CHEMS ADDED			MAINTENANCE		
	Free Cl 1-10ppm Spa 2-10	Total Cl	Comb. Cl < 0.5 ppm	pH 7.2 – 7.8	Temp Max 104°F	Flow Meter GPM	Suction Outlets Close pool if loose, missing, or broken Check daily	Alk. > 50 ppm	CYA < 100 ppm	Sanitizer Interlock Check weekly	Type	Amt.	Back Wash	Press. PSI	Other i.e. H ₂ O added
1															
2															
3															
4															
5															
6															
7															
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															
22															
23															
24															
25															
26															
27															
28															
29															
30															
31															