

# HENNEPIN COUNTY

## MINNESOTA

### PUBLIC SWIMMING POOL CHEMISTRY REQUIREMENTS

<b>Disinfectant</b>	<b>Swimming &amp; Wading Pools</b>	<b>Spa Pools</b>
Free Chlorine	1.0 - 10.0 ppm	2.0 - 10.0 ppm
Bromine	2.0 - 20.0 ppm	4.0 - 20.0 ppm

pH: 7.2 - 7.8	Combined chlorine: 0.5 ppm maximum
Alkalinity: 50 ppm minimum	Cyanuric acid: 100 ppm maximum
Water clarity: Bottom drain must be clearly visible	Temperature: 104°F maximum

#### Hennepin County Public Health

479 Prairie Center Dr., Eden Prairie, MN 55344

612-543-5200

[www.hennepin.us/pools](http://www.hennepin.us/pools)

